

INSPECTION FREQUENCY TABLE



www.boyerfire.com

618-222-1500 | 314-241-9944 | 608-424-8420

Office Locations: Missouri | Illinois | Wisconsin

LIFE SAFETY ITEM	INSPECTION INTERVAL	CODE / STANDARD
FIRE EXTINGUISHERS	MONTHLY QUICK CHECK ANNUAL INSPECTION	NFPA 10 NFPA 10
EMERGENCY AND EXIT SIGNS	MONTHLY QUICK CHECK ANNUAL INSPECTION	NFPA 101 NFPA 101
BACKFLOWS	ANNUAL TEST	NFPA 13, NFPA 25, PLUMBING CODE'S AND LOCAL AUTHORITIES
SPRINKLER SYSTEMS	QUARTERLY INSPECTION ANNUAL INSPECTION	NFPA 25 NFPA 25
STANDPIPE SYSTEMS	SEMI ANNUAL INSPECTION ANNUAL INSPECTION	NFPA 25 NFPA 25
KITCHEN HOOD SUPPRESSION SYSTEMS	SEMI ANNUAL INSPECTION ANNUAL INSPECTION	NFPA 17A NFPA 17A
FIRE ALARM	SEMI ANNUAL INSPECTION ANNUAL INSPECTION	NFPA 72
FIRE PUMP	MONTHLY CHURN ANNUAL INSPECTION	NFPA 25 NFPA 25